



**MARTIN
COUNTY**

**Fresh Water
Supply District No. 1**

PO Box 146 | Lenorah, TX 79749

admin@martincountyfwd.com

operations@martincountyfwd.com

Office: (432) 459-2266

Operator: (432) 270-5119

Administrator: (432) 268-0085

**Failure to Submit a Disinfectant Level Quarterly Operating Report
(DLQOR)
MONITORING, ROUTINE (DBP), MAJOR/CHLORINE**

The **MARTIN COUNTY FWSD 1** water system PWS ID 1590002 has violated the monitoring/reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

This violation occurred in the monitoring period, *second quarter of 2026*.

We have taken the following actions to address this issue:

Due to a transition in operational responsibilities, an oversight occurred in the timely filing of the second quarter 2026 DLQOR. The maintenance and monitoring of disinfectant residuals remained a priority throughout this transition and were not interrupted. The required report has since been completed and submitted.

The District has established a reporting calendar to track required reporting deadlines and help ensure all future reports are submitted in a timely manner.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Trevin Martin (District Operator) at (432) 270-5119.

Posted/Delivered on: **10/30/2026**